

i.e. B – s2 , d0

**Reaction to fire classification: B – s2, d0**

**4.3 Field of application**


This classification is valid for the following end use applications:

- i) Wall or Ceiling Applications, used behind any substrate with a fire performance of A2 or better and a density equal to or greater than 800kg/m<sup>3</sup>.
- ii) Wall or Ceiling Applications, used as part of a built up system as described in Clause 2.2.

This classification is also valid for the following product parameters:

Plasterboard	No variation from tested specification
Battens	No variation from tested specification
Super Polynum Insulation	No variation from tested specification
Built up system	No variation from tested configuration

**SIGNED**



.....  
**Leigh Hill**  
Technical Officer  
Technical Department

**APPROVED**



.....  
**Janet Murrell**  
Technical Manager  
Technical Department  
on behalf of  
**Warrington Fire Research Centre**