DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6210BT0171
Registration Number
Registriernummer

Field of Application ***Anwendungsbereich***	products of water supply *Produkte der Wasserversorgung*
Owner of Certificate ***Zertifikatinhaber***	FRIATEC AG Steinzeugstr. 50, D-68229 Mannheim
Distributor ***Vertreiber***	FRIATEC AG Steinzeugstr. 50, D-68229 Mannheim
Product Category ***Produktart***	valves for water supply: valves for water supply, made of PE (6210)
Product Description ***Produktbezeichnung***	valve made of PE-HD for the drinking water supply
Model ***Modell***	FRIALOC
Test Reports ***Prüfberichte***	mechanical test: A0 043/15 from 23.11.2015 (TZW) mechanical test: A0 015/11 from 25.07.2011 (TZW) mechanical test: A0 011/08 from 06.06.2009 (TZW) type testing: A 010/07 from 14.03.2008 (TZW)
Test Basis ***Prüfgrundlagen***	DVGW W 364 (01.06.2010) DIN EN 1074-1 (01.07.2000) DIN EN 1074-2 (01.07.2004) UBA METALLE (19.01.2016) BGA KTW (12.12.1985) UBA KTW (07.10.2008) DVGW W 270 (01.11.2007)
Date of Expiry / File No. ***Ablaufdatum / Aktenzeichen***	14.03.2021 / 16-0127-WNV

70028-04-A-DE

22.04.2016 GI A-1/2 i.A. A. Uhlig

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.

DAkkS
Deutsche Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type *Typ*	Technical Data *Technische Daten*	Remarks *Bemerkungen*
FRIALOC	pressure rating: PN 16 nominal diameter: DN 80	
FRIALOC	pressure rating: PN 16 nominal diameter: DN 100	
FRIALOC	pressure rating: PN 16 nominal diameter: DN 150	

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

nominal diameter: DN 80 - Nominal outer diameter of the weld-on end: d 90
nominal diameter: DN 100 - Nominal outer diameter of the weld-on end: d 90
nominal diameter: DN 100 - Nominal outer diameter of the weld-on end: d 110
nominal diameter: DN 100 - Nominal outer diameter of the weld-on end: d 125
nominal diameter: DN 150 - Nominal outer diameter of the weld-on end: d 160
nominal diameter: DN 150 - Nominal outer diameter of the weld-on end: d 180