ÖVGW
ÖSTERREICHISCHE VEREINIGUNG
FÜR DAS GAS- UND WASSERFACH

Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schubertring 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at

ÖVGW GEPRÜFT

Accredited by the Federal Ministry
of Science, Research and Commerce

Akkreditierung Austria 0922 EN 45011

ÖVGW Certificate

of the conferment of the right to use the ÖVGW Quality Mark for Gas

Registration number

G 2.718

Period of validity

until the end of October 2016

Owner

Bänninger Kunststoff-Produkte GmbH
Bänninger Straße 1
35447 Reiskirchen
DEUTSCHLAND

◆ **Distribution in Austria**

Glynwed GmbH
Birostraße 13
1230 Wien

Bayerl GmbH
Alte Wiener Straße 54
2640 Bruck/Leitha

Manufacturer

Bänninger Kunststoff-Produkte GmbH / DE

Type of test

Renewal and supplementary test

Reason for the supplement

Dimensions d_n 450, 500, 560 and 630 mm
in SDR 11 and SDR 17

Test report

410.009-5 dated 4 May 2014

Quality standards / Testing directives

- QS-G 392/3 (May 2013 version)

Product

Longitudinally shaped pieces made of high-density polyethylene (PE 100) for heating-element butt welding and heating-coil welding, having the following dimensions:

d_n 32, 40, 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560 and 630 mm
in SDR 11 with MOP 10

as well as

d_n 32, 40, 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560 and 630 mm
in SDR 17 with MOP 6

for gas supply systems

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products "Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 28 May 2014

Dipl-Ing (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office

ZVR 818158001