Certificate

kiwa
Partner for progress

Number	87809/01	Replaces	--
Issued	09-07-2015	Scope	KE 52
Contract number	Q 15/003	Page	1-2

Product Certificate

Soft sealing gate valves Series 3000

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

Fucoli-Somepal - Fundição de Ferro, S.A.

may, on delivery, be relied upon to comply with the GASTEC QA Approval Requirements 52, "valves for gas distribution systems with a maximum operating pressure less than or equal to 16 bar " dated October 2013.

B. Meekma

Bouke Meekma
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Product Certification.

This certificate consists of 2 pages.
Publication of the certificate is allowed.

Kiwa Nederland B.V.
Wilmersdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands
Tel.+31- 55 539 33 55
Fax +31- 55 539 36 76
www.kiwa.nl

PRODUCTS
RvA C 002

Company
Fucoli-Somepal - Fundição de Ferro, S.A.
Apartado 467 - Coselhas
3001-906 Coimbra
Portugal
www.fucoli-somepal.pt

T +351 239 490100
F +351 239 490198

GASTEC QA

Soft sealing gate valves Series 3000

PRODUCT SPECIFICATION

Series 3000 flanged type 14 and type 15.
DN 40, 50, 60, 65, 80, 100, 125, 150, 200, 250, 300
Operating pressure 16 bar.

Series 3000 with PE spigot ends PE 100, SDR11/ SDR17.
DN 50, 65, 80, 100, 125, 150, 200, 250, 300
Operating pressure 10 bar.

APPLICATION AND USE

Gas distribution valves with a maximum operating pressure less than or equal to 16 bar. The valves are for use in gas installations for 1st family gases (town gas) and 2nd family gases (natural gas). The specific functional recommendations for application of these valves in gas supply systems are described in NEN 7244, NEN-EN 12007 and national and international norms and/or regulations.

MARKING

Compulsory specifications:

- Manufacturer's name or trademark (possibly a symbol),
- PN 10 or PN 16,
- Nominal size DN,
- Traceability identification,
- The quality mark i.e. GASTEC QA or GASTEC QA logo.

Place of the mark:

- On the body of the valve in a clearly visible position.

Method of marking:

- Non-erasable.

1. Check at the time of delivery whether:
   - 1.1 the producer has delivery in accordance with the agreement;
   - 1.2 the mark and the marking method are correct;
   - 1.3 the products show no visible defects as a result of transport etc.

2. If you should reject a product on the basis of the above, please contact:
   - 2.1 Fucoli Somepal - Fundição de Ferro, S.A.
     and, if necessary,
   - 2.2 Kiwa Nederland B.V.

3. Consult the producer's processing guidelines for the proper storage and transport methods.

4. Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.