


Loss Prevention Certification Board



This is to certify

PITTWAY TECNOLOGICA Srl
Via Caboto 19/3, 34147 Trieste, Italy

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

M210E, M220E, M221E, M201E, M201E-240 and M201E-240-DIN input/output modules and M210E-CZ conventional zone interface module
(refer to attached appendix for details)

which have complied with the requirements of the following:

CEA GEI 1-052 Draft 2.0 – Test methods for short circuit isolating devices and input/output devices

CEA GEI-084 Draft : 08.08.00 – Requirements and test methods for input/output devices. Specifications for fire detection and fire alarm systems. Requirements and test methods for input/output devices for use on the transmission paths of fire detection and fire alarm systems

prEN 54-17 Draft : July 2002 – Fire detection and fire alarm systems: short circuit isolators

Certificate No. 199q

Issue No. 04

Date of Issue 15 August 2006

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: E MATTIE-SULEIMAN



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 199q

PITWAY TECNOLOGICA Srl

Products

LPCB Ref. No.

M210E analogue addressable single channel input module with short circuit isolator	199q/01
M220E analogue addressable dual channel input module with short circuit isolator	199q/02
M221E analogue addressable dual channel input and single channel output module with short circuit isolator	199q/03
M201E single channel output module with short circuit isolator	199q/04
M201E-240 single channel 240V output module with short circuit isolator	199q/05
M201E-240-DIN single channel 240V output module, DIN rail mount with short circuit isolator	199q/06
M210E-CZ analogue addressable conventional zone interface module	199q/07

For details of Cross-Listed products and alternative branding please see page 3.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: E MATTIE-SULEIMAN

Page 2 of 3

Date of Issue 15 August 2006

Issue No. 04

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 199q

PITWAY TECNOLOGICA Srl

LPCB Ref. No.	Model No.	Alternative Model No.	Labelled
199q/01	M210E MI-DMMI	M710	Notifier Morley
199q/02	M220E MI-DMM2I	M720	Notifier Morley
199q/03	M221E	M721 MI-D2ICMO	Notifier Morley
199q/04	M201E	M701 MI-DCMO	Notifier Morley
199q/05	M201E-240	M701-240 MI-D240CMO	Notifier Morley
199q/06	M201E-240-DIN	M701-240-DIN MI240CMO-DIN	Notifier Morley
199q/07	M210E-CZ	EM210ECZ MI-DCZM M710-CZ TC841E1019	OY ESMI AB Morley Notifier Honeywell Control Systems Ltd

For details of Cross-Listed products and alternative branding please see page 3.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 3 of 3

Date of Issue 15 August 2006

Issue No. 04

Name: E MATTIE-SULEIMAN

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.