



Certificate

of Approval of Components and Systems

Holder of the Approval:

Honeywell Life Safety Austria GmbH
Lemböckgasse 49
AT-1230 Wien

Approval No.:	No. of pages:	Valid from:	Valid to:
G 210122	39	23.12.2010	22.12.2014

Subject matter of the Approval:

Voice Alarm Control and Indicating Equipment
Type VARIODYN D1

Use:

in Automatic Fire Detection and Fire Alarm Systems

Basis for approval:

DIN EN 54-16:2008-06 - Voice Alarm Control and Indicating Equipment
DIN EN 54-4:1997-12 + A1:2003-03 + A2:2007-01 - Power Supply Equipment
VdS 2541:1996-12 - Power Supply Equipment
VdS 2344:2005-12 - Procedure Guidelines

This approval is valid only for the specified component/system as submitted for the test

- together with the parts listed in enclosure 1
- documented in the technical papers acc. to enclosure 2 (r/a for systems)
- for application in the specified fire protection and security installations. Use of the subject matter of the approval, is subject to the hints/comments of enclosure 3.

The validity of the approval can be extended upon application. Application for extension shall be submitted six months before expiry of the current approval at the latest.

This certificate may only be reproduced in its present form without any modification including all enclosures. All changes of the underlying conditions of this approval shall be reported at once to the VdS Certification Body enclosing the required documentation.

Any advertising with this VdS approved component/system shall reflect the correct contents of the certificate and shall not violate the trade practice rules.

Köln (Cologne), 23.12.2010


Schüngel

Managing Director



i. V. Hesels

Head of the VdS Certification Body

VdS Schadenverhütung GmbH
Zertifizierungsstelle
Amsterdamer Str. 174
D-50735 Köln

A company of the German Insurance Association (GDV) (German federation of insurance companies)

Accredited by the "Deutsche Akkreditierungsstelle Technik (DATech)" as a certification body for the areas of fire protection and security



DAT-ZE 005/92