

Pepperl+Fuchs GmbH  
Lilienthalstraße 200  
68307 Mannheim  
Germany  
Phone +49 621 776-0  
Fax +49 621 776-1000

No. / Nr.: DOC-0772B  
Date / Datum: 2016-05-13

Copyright Pepperl+Fuchs  
www.pepperl-fuchs.com



### Declaration of conformity / Konformitätserklärung

We, Pepperl+Fuchs GmbH declare under our sole responsibility that the **products** listed below are in conformity with the listed **European Directives and standards**.

Die Pepperl+Fuchs GmbH erklärt hiermit in alleiniger Verantwortung, dass die unten gelisteten **Produkte** den genannten **Europäischen Richtlinien und Normen** entsprechen.

### Products / Produkte

Product / Produkt	Item number	Description / Beschreibung
KFD0-CS-EX1.50P	072143	Repeater
KFD0-CS-EX2.50P	072145	Repeater
KFD0-CS-EX1.51P	072147	Current Driver / Repeater
KFD0-CS-EX2.51P	072149	Current Driver / Repeater
KFD0-CS-EX2.51P-Y107439	107439	Current Driver / Repeater
KFD0-CS-EX1.53	072150	Current Driver
KFD0-CS-EX2.53	072152	Current Driver

### Directives and Standards / Richtlinien und Normen

EU-Directive EU-Richtlinie	Standards Normen
2014/30/EU (EMC)	EN 61326-1:2013 (industrial location)
2014/34/EU (ATEX)	EN 60079-0:2012 + A11:2013 EN 60079-11:2012 EN 60079-15:2010

### Affixed CE Marking / Angebrachte CE-Kennzeichnung



### Signatures / Unterschriften

Mannheim, 2016-05-13

ppa. M. Kessler i.V. W. Bansemir

ppa. Michael Kessler  
Vice President Business Unit  
Components and Technology

i.V. Werner Bansemir  
Manager Interface Technology

### ANNEX (ATEX)

#### Notified Body QM-System / Notifizierte Stelle des QM-Systems:

Physikalisch Technische Bundesanstalt (0102)  
Bundesallee 100  
38116 Braunschweig  
Germany

We, Pepperl+Fuchs GmbH declare that the products are only affected by minor or formal changes in respect to the new edition of the standards. These changes are not relevant for compliance with the EHSRs and consequently the products still comply with the ATEX Directive.

Die Pepperl+Fuchs GmbH erklärt hiermit, dass die Produkte nur von kleineren oder formalen Änderungen in Bezug auf die neue Ausgabe der Normen betroffen sind. Diese Änderungen sind nicht relevant für die Konformität mit den EHSRs, weshalb die Produkte nach wie vor die ATEX-Richtlinie erfüllen.

The Type-Examination Certificate TÜV 99 ATEX 1499 X and the marking of the equipment was performed in accordance with the following standards:

Die EG-Baumusterprüfung und die Kennzeichnung des Betriebsmittels wurden nach den folgenden Normen durchgeführt:

EN 60079-0:2006  
EN60079-15:2005

### Marking and Certificates / Kennzeichnung und Zertifikate

Products / Produkte	KFD0-CS-EX*.5*P*	
Marking Kennzeichnung	Certificate Zertifikat	Issuer ID Aussteller ID
⊕ II (1) G ⊕ II (1) D ⊕ I (M1)	BAS 98 ATEX 7343	1180
⊕ II 3 G	TÜV 99 ATEX 1499 X	TÜV

### Key for Issuer ID / Schlüssel zur Aussteller ID

ID	Issuer / Aussteller
1180	Baseefa Ltd. Rockhead Business Park, Staden Lane Buxton Derbyshire SK17 9RZ England
TÜV	TÜV NORD CERT GmbH Langemarkstraße 20 45141 Essen Germany