

Certificate of Compliance

Certificate Number 121205 - S7197
Report Reference S7197, August 22nd, 1998
Issue Date 2005 December 12

Page 1 of 1



Issued to: **SECURITON AG**
ALPENSTRASEE 20
3052 ZOLLIKOFEN SWITZERLAND


This is to certify that representative samples of **Heat Detector for Special Applications**
Models ADW511 and ADW511A

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **UL 521 - Heat Detectors for Fire Protective Signaling Systems**

Additional Information: Ratings -
Electrical - Input rating - 10.5-30 V dc, 100 mA

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *D. M. Grosch*
D. M. Grosch, Engineering Associate

UL International Germany GmbH

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in Germany, you may call +49 0 6102 369 0.

Reviewed by: *J. L. Parssinen*
J. L. Parssinen, Engineering Group Leader

UL International Germany GmbH