

im. Józefa Tuliszkowskiego - PAŃSTWOWY INSTYTUT BADAWCZY

Jednostka Certyfikująca / Certification Department

ul.. Nadwiślańska 213, 05-420 Józefów



NATIONAL CERTIFICATE OF CONSTANCY OF PERFORMANCE No. 063-UWB-0074

In accordance with the regulation of the Minister of Infrastructure and Construction of 17 November 2016 on the manner of declaring performance of construction products and marking them with the construction mark (Journal of Laws, item 1966), this certificate applies to a construction product:

Fire detector – to be used in building facilities – Resettable line-type heat detector type d-LIST

<levels and classes of performance, description and conditions for use of the construction product, see the following pages of the certificate>

covered by the Polish Standard for the product:

PN-EN 54-22:2015-07 Fire Detection And Fire Alarm Systems Part 22: Resettable Line-Type Heat Detectors

placed on the market under the manufacturer's name or trademark:

Listec GmbH
Am Sandberg 34
84424 Isen, Federal Republic of Germany

represented by an authorized representative: Schrack Seconet Polska Sp. z o.o.

ul. Domaniewska 44a

02-672 Warszawa, Republic of Poland

and manufactured in the manufacturing plant:

Listec GmbH
Am Sandberg 34
84424 Isen, Federal Republic of Germany

This certificate confirms that all provisions resulting from national system 1 regarding the assessment and verification of constancy of performance in relation to the declared performance of the product related to its measured application defined in this certificate are applicable and that:

the Manufacturer has implemented a factory production control system to ensure that these properties are maintained.

This certificate was issued for the first time on 22/12/2017 and remains in force until 21 December 2027, provided that the Manufacturer complies with the requirements contained in the agreement No. 74/DC/B/2017 of 22 December 2017, and until the Polish Standard for the product, methods for assessment and verification of constancy of performance, the construction product itself and its manufacturing conditions do not change, and that it will not be suspended or withdrawn by an accredited product certification body.

Certificate issue number: 01

Issue date: 22.12.2017

The validity of this certificate can be confirmed on the institute website at www.cnbop.pl or by telephone: 48 22 769 33 45.

MANAGER

OF THE CERTIFICATION DEPARTMENT

DIRECTOR OF CHBOP-PIB

In place of

the Deputy Manager of the Certification Department

Michał Chmiel, MSc.

bryg Dariusz Wroblewski, PhD Eng.

This document was originally translated from Polish to English on 6 August 2018.

In case of conflict between the Polish Certificate of Conformity and this translation, the Polish document shall be binding.

DC/29a/14.02.2017



im. Józefa Tuliszkowskiego - PAŃSTWOWY INSTYTUT BADAWCZY

Jednostka Certyfikująca / Certification Department

ul.. Nadwiślańska 213, 05-420 Józefów



NATIONAL CERTIFICATE OF CONSTANCY OF PERFORMANCE No. 063-UWB-0074

Fire detector – to be used in building facilities – Resettable line-type heat detector type d-LIST

Levels and classes of performance, description and conditions for use of the construction product:			
Performance	Chapter PN-EN 54-22:2015-07	Level, class	
General requirements	4.1	fulfills	
Individual alarm indication	4.2.1	fulfills	
Signalling	4.2.2	fulfills	
Repeatability	4.2.3	fulfills	
Reproducibility	4.2.4	fulfills	
Connection of auxiliary devices	4.3.1	fulfills	
Manufacturer's adjustments	4.3.2	fulfills	
Requirements for software controlled detectors	4.3.3	fulfills	
Sensing element fault	4.3.4	fulfills	
On-site adjustment of response bahaviour	4.3.5	fulfills	
Maximum ambient temperature test (sensing element)	4.3.6	fulfills	
Variation in supply parameters	4.4.1	fulfills	
Low voltage fault	4.4.2	fulfills	
Fire sensitivity for room protection application	4.5.1	fulfills	
Static response temperature test	4.5.2	fulfills	

Certificate issue number: 01

Issue date: 22.12.2017

The validity of this certificate can be confirmed on the Institute's website at www.cnbop.pl or by telephone: 48 22 769 33 45.

MANAGER

OF THE CERTIFICATION DEPARTMENT

DIRECTOR OF CNBOP-PIB

In place of

bryg Dariusz Wróblewski, PhD Eng.

the Deputy Manager of the Certification Department

Michał Chmiel, MSc.

This document was originally translated from Polish to English on 6 August 2018.

In case of conflict between the Polish Certificate of Conformity and this translation, the Polish document shall be binding.

DC/29a/14.02.2017



im. Józefa Tuliszkowskiego - PAŃSTWOWY INSTYTUT BADAWCZY

Jednostka Certyfikująca / Certification Department

ul.. Nadwiślańska 213, 05-420 Józefów



NATIONAL CERTIFICATE OF CONSTANCY OF PERFORMANCE No. 063-UWB-0074

Fire detector – to be used in building facilities – Resettable line-type heat detector type d-LIST

Levels and classes of performance, description
and conditions for use of the construction product:

and conditions for use of the construction product:			
Performance	Chapter of PN-EN 54-22:2015-07	Level, class	
Dry heat (operational) – sensor control unit	4.6.1.1	fulfills	
Dry heat (endurance) – sensing element	4.6.1.2	fulfills	
Cold (operational) – sensing element	4.6.1.3	fulfills	
Cold (operational) – sensor control unit	4.6.1.4	fulfills	
Damp heat, steady state (endurance) – sensor control unit and sensing element	4.6.2.1	fulfills	
Damp heat, cyclic (operational) – sensing element	4.6.2.2	fulfills	
Damp heat, cyclic (operational) – sensor control unit	4.6.2.3	fulfills	
Damp heat, steady state (operational) – sensor control unit	4.6.2.4	not applicable	
Damp heat, cyclic (endurance) – sensor control unit and sensing element	4.6.2.5	fulfills	
Shock (operational) – sensor control unit	4.6.3.1	fulfills	
Impact (operational) - sensor control unit	4.6.3.2	fulfills	
Impact (operational) - sensing element	4.6.3.3	fulfills	
Vibration, sinusoidal (operational) – sensor control unit	4.6.3.4	fulfills	
Vibration, sinusoidal (operational) – sensing element	4.6.3.5	fulfills	
Vibration, sinusoidal (endurance) – sensor control unit	4.6.3.6	fulfills	
Vibration, sinusoidal (endurance) – sensing element	4.6.3.7	fulfills	
Sulphur dioxide (SO ₂) corrosion (endurance) – sensing element	4.6.4.1	fulfills	
Sulphur dioxide (SO ₂) corrosion (endurance) – sensor control unit	4.6.4.2	fulfills	
Electromagnetic immunity	4.6.5.1	fulfills	

Certificate issue number: 01

Issue date: 22.12.2017

The validity of this certificate can be confirmed on the Institute's website at www.cnbop.pl or by telephone: 48 22 769 33 45.

MANAGER

OF THE CERTIFICATION DEPARTMENT

DIRECTOR OF CHBOP PIB

In place of

the Deputy Manager of the Certification Department

bryg, Dariusz Wróblewski, PhD Eng.

Michał Chmiel, MSc.

This document was originally translated from Polish to English on 6 August 2018. In case of conflict between the Polish Certificate of Conformity and this translation, the Polish document shall be binding.



im. Józefa Tuliszkowskiego - PAŃSTWOWY INSTYTUT BADAWCZY

Jednostka Certyfikująca / Certification Department

ul.. Nadwiślańska 213, 05-420 Józefów



NATIONAL CERTIFICATE OF CONSTANCY OF PERFORMANCE No. 063-UWB-0074

Fire detector – to be used in building facilities – Resettable line-type heat detector type d-LIST

Levels and classes of performance, description

and conditions for use of the construction product: Description of the product d-LIST Maximum length of the detection wire: 0,25 km metal - SCU 800-03, SCU 800/16 controller: metal - ESD-A5-EL prismatic external sensor. Housing material: ESD-A5-RL cylindrical external sensor; plastic - CBO 5-ESD-T, CBO 5-SEC connection module 260 x 150 x 90 mm - SCU 800-03, SCU 800/16 controller; Ø 8 x 50 mm - ESD-A5-EL prismatic external sensor, Dimensions (width x height x length): ESD-A5-RL cylindrical external sensor; 130 x 130 x 75 mm - CBO 5-ESD-T, CBO 5-SEC connection module Weight: 1,9 kg - 10°C ÷ + 55°C - sensor control unit Working temperature range: - 25°C ÷ + 70°C - sensing element II - sensor control unit Environmental group: II lub III - sensing element Range of work voltages: 21 ÷ 29 V DC Power consumption in the supervision mode: 80 mA Power consumption during fire alarm: 100 mA Power consumption during fault signalling: 100 mA Type of detection wire: SEC 15 sensory cable Topology of the measuring line: open lines 1, 2, 3, 4, 5 m - standard Measurement resolution: (other chosen freely depending on the order - at least 0.25 m)

Certificate issue number: 01

Issue date: 22.12.2017

The validity of this certificate can be confirmed on the institute's website at www.cnbop.pl or by telephone: 48 22 769 33 45.

MANAGER
OF THE CERTIFICATION DEPARTMENT

Operating class (room protection application):

Operating class (local protection application):

DIRECTOR OF CNBOP-PIB

A1N, A2N

BN

V1

In place of

Software version:

the Deputy Manager of the Certification Department Michał Chmiel, MSc.

bryg, Dariusz Wróblewski, PhD Eng.

This document was originally translated from Polish to English on 6 August 2018. In case of conflict between the Polish Certificate of Conformity and this translation, the Polish document shall be binding.