



Certificate of constancy of performance

0099/CPR/A74/0077

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

EASY DETECT, S.L

registered office PASSEIG DELS FERROCARRILS CATALANS, 143 08940 CORNELLÀ DE LLOBREGAT (Barcelona - España)

Construction Product **Power supply equipment**

Harmonised Standard EN 54-4:1997
EN 54-4:1997/AC:1999
EN 54-4:1997/A1:2002
EN 54-4:1997/A2:2006

References Specified in Annex to the Certificate

Production site CALLE DE LOS RESTAURADORES, 8 28830 SAN FERNANDO DE HENARES (Madrid - España)

Certification scheme This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonised standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

This certificate supersedes A74/000077, dated 2025-07-16

First issued on 2009-07-16
Modified on 2026-04-14
Validity 2026-07-16

Rafael GARCÍA MEIRO
CEO






Certificate of constancy of performance

0099/CPR/A74/0077

Annex to Certificate

Trade Mark	Model/reference	Supply voltage	Frecuency	Output voltage/current	Output	Electric safety class
AGUILERA	AE/FL-2A	220/240 VAC	50/60 Hz	27,2 VDC	65 W	CLASE I
AGUILERA	AE/FL-5A	220/240 VAC	50/60 Hz	27,2 VDC	150 W	CLASE I
AGUILERA	AE/SA-FA	220/240 VAC	50/60 Hz	27,2 VDC	150 W	CLASE I
AGUILERA	AE/SA-FA2	220/240 VAC	50/60 Hz	27,2 VDC	65 W	CLASE I
AGUILERA	AE/94-FA	220/240 VAC	50/60 Hz	27,2 VDC	150 W	CLASE I
AGUILERA	AE/94-FA2	220/240 VAC	50/60 Hz	27,2 VDC	65 W	CLASE I

First issued on 2009-07-16
Modified on 2026-04-14
Validity 2026-07-16



AENOR CONFÍA S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com