ZERTIFIKAT ◆ CERTIFICATE ◆ 認証書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

Attestation of Conformity

No. N8 10 08 73900 006

Holder of Certificate: **Zhejiang Chint Electrics Co., Ltd.**
No.1, Chint Road, Chint Industrial Zone North Baixiang
325603 Yueqing, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Molded case circuit breakers**

Model(s): **NM8S-1250S, NM8S-1250H**

Parameters:

Rated voltage:	415V, 690V
Rated frequency:	50/60Hz
Rated current:	630A,700A,800A,1000A,1250A
Poles No.:	3P
Degree of protection:	IP20
Product information:	NM8S-1250S: Ics= 25kA(415V),5kA(690V) NM8S-1250H: Ics= 35kA(415V),10kA(690V) NM8S-1250S: Icu= 50kA(415V),10kA(690V) NM8S-1250H: Icu= 70kA(415V),20kA(690V) Ui=750V, Uimp= 8kV, Cat.A

Tested according to: EN 60947-2/A1:2009

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704101027507-00

438570

Date, 2010-08-09 (Roy Yongjun Xue)

CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

TÜV SÜD Product Service GmbH · Zertifizierstelle · Ridlerstraße 65 · 80339 München · Germany

TÜV®